



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
architects@beilharzinc.com

March 29, 2023

DEFIANCE COUNTY EAST
Storage Building
Defiance, Ohio

C2-4854

ADDENDUM 1

This Addendum becomes a part of the Contract Documents and modifies them only to the extent herein set forth. Bidders shall acknowledge receipt of this Addendum on the Bid Form. Each bidder is responsible for distribution of information conveyed by this Addendum to its subbidders and suppliers.

Attachments: Drawings C-102, E-101 (revised)
Bid Question Log #1

ITEM NO. 1: Section 074313 – Metal Roof and Wall Panels

Paragraph 2.01: Add McElroy Metal, Inc. and Ramco Supply.

Paragraph 2.05.B: Add MFM Building Products Corp.; Ultra HT Wind & Water Seal.

ITEM NO. 2: Sheet C-101 – Site Demolition Plan

Revise Keynote 3 to read: Remove light pole and abandon overhead power from Existing Building #2. Rework underground electric as necessary to maintain energized system for balance of light fixtures to remain; refer to Electrical.

ITEM NO. 3: Sheet C-102 – Site Utility Plan

Refer to attached revised Drawing for underground electrical to existing light poles. Refeed existing site lighting from new building.

ITEM NO. 4: Sheet E-101 – Electrical Plan, Schedules, and Details

Refer to attached revised Drawing for circuiting and controls for existing site lighting and building exterior lighting.

END OF ADDENDUM



701½ West First Street
Defiance, OH 43512
Phone 419-782-6211
architects@beilharzinc.com

March 29, 2023

DEFIANCE COUNTY EAST
Storage Building
Defiance, Ohio

C2-4854

BID QUESTION LOG #1

The following questions and answers are distributed for supplemental information and clarification, and are not part of the Contract Documents. Questions answered by Addendum items are not necessarily repeated in this document.

- Q1. Is a temporary fence required during the construction of the project?
- A. The Owner recommends but does not require the temporary construction fence.
- Q2. Were you wanting a separate gas line and new meter at the new building, or just a fuel line coming off the existing meter set of existing building #1?
- A. Include the gas line and meter as shown on C-102 and M-101. Tie into the existing gas line before the Existing Building #1 meter.

pEND OF BID QUESTION LOG #1